

## **GOVT.OF ASSAM** STATE PUBLIC HEALTH LABORATORY, ASSAM **BAMMUNIMAIDAM, GUWAHATI-21**

Email: foodanalyst@sphlassam.org
Office Contact No. +91 7099015100

Website: www.sphlassam.org

No.VII.6(III)/20-21/ 322(

Dated Guwahati, the 02/06

## REPORT ON ANALYSIS OF DRINKING WATER (IS 10500:2012)

Laboratory Code No.

: Chem. 622/22

**Customer Name & Address** 

: Cambridge Public School, Add. Sundarbari, Jalukbari,

Guwahati- 781014, Dist. Kamrup(M) (Assam)

**Sample Description** 

: Bisleri (Supply)

**Date of Receipt** 

: 06/05/2022

**Date of Analysis** 

: Start: 31/05/2022:

Fnd: 31/5/2022

the state of the s	. Start.	31/05/2022;	End	End: 31/5/2022	
SI. No.	Parameter	Nature of method used	Result	Desirable limit	
1	Appearance	FSSAI Manual	Clear	Clear	
2	Odour	-do-	Unobjectionable	Unobjectionable	
3	Taste	-do-		Agreeable	
4	Turbidity, ити	-do-	0	5(Max) (mg/l)	
5	рН	-do-	7.2	6.5 to 8.5 (mg/l)	
6	Total hardness (as CaCo <sub>3</sub> ),mg/1	-do-	36	200(Max) (mg/l)	
7	Iron	-do-	0.02	0.30 (Max) (mg/l)	
8	Chlorides (as Cl), mg/1	-do-	3	250 (Max) (mg/l)	
9	Residual free Chlorine, mg/1	-do-	Nil	0.20 (Max) (mg/l)	
10	Fluoride (as F), mg/1	-do-	0.3	1.0 (Max) (mg/l)	
11	Dissolved Solids, mg/1	-do-	63	500 (Max) (mg/l)	
12	Calcium (as Ca) mg/1	-do-	8	75 (Max) (mg/l)	
13	Magnesium (as Mg), mg/1	-do-	3.9	30 (Max) (mg/l)	
14	Manganese (as Mn), mg/1	-do-	Nil	0.10 (Max) (mg/l)	
15	Sulphate (as SO <sub>4</sub> ), mg/1	-do-	Nil	200 (Max) (mg/l)	
16	Nitrates (as NO <sub>3</sub> ), mg/1	-do-	Nil	45 (Max) (mg/l)	
17	Phenolic Compounds (as C <sub>6</sub> H <sub>5</sub> OH)	-do-	Nil	0.001(Max) (mg/l)	
18	Mineral Oil, mg/1	-do-	Nil	0.50 (Max) (mg/l)	
19	Alkalinity as (CaCO <sub>3</sub> ) mg/1	-do-	66	200 (Max) (mg/l)	

Note: Results are only with respect to the items tested. All tests are performed in the laboratory location only. Results apply to the sample as received.

OPINION: THE SAMPLE IS CHEMICALLY SATISFACTORY WITH RESPECT TO THE TESTS CARRIED OUT.



Food Analyst to the Govt. of Assam Bamunimaidam, Guwahati- 21

The report shall not be reproduced except in full, without the approval of the laboratory.

---End of Report---